

GOVERNMENT OF TELANGANA
INTERNAL WATER QUALITY MONITORING LABORATORY
MB, INTRA-DIVISION :: MAHABUBNAGAR
CHEMICAL ANALYSIS REPORT AS Per IS:10500-2012

Sample collected by:

Sl.No.	Lab.Re- f.No.	Date	Name of the Mandal	Panchayath	Habitation	Location	Sources	Turbidi- ty (1-5 NTU)	PH limits between (6.5- 8.5)	Total Dislved Solids Desirabl e limit 500 mg/lit & Permissi- ble limit 2000 mg/lit	Total Alkalinity as CaCO3 Desirable limit 200 mg/lit & Permissible limit 600 mg/lit	Total Hardness as CaCO3 Desirable limit 300 mg/lit & Permissible e limit 600 mg/lit	Fluoride as F Desirabl e limit 1.0 mg/lit & Permissi- ble limit 1.50 mg/lit	Chloride Desirabl e limit 250 mg/lit & Permissi- ble limit 1000 mg/lit	Nitrate as NO3 Desirabl e limit 45 mg/lit & Permissi- ble limit is No relaxati- on	Sulphat e as So4 Desirabl e limit 200 mg/lit & Permissi- ble limit 400 mg/lit	Iron as Fe Desirabl e limit 0.3 mg/lit & Permissi- ble limit is 1.0 mg/lit	Remarks		
1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21
1	8279	17.02.2026	Mahabubnagar	Mahabubnagar	Yenugonda	Sri Chaitanya school CBSE Opposite Pista house	Bore Water	0.10	7.62	554		284	328	1.39	144	13	65	0.02	Satisfactory	


CHEMIST
MB, Intra District WQM Lab,
Mahabubnagar.



**OFFICE OF THE MAHABUBNAGAR
MUNICIPAL CORPORATION**



File. No.F1/E-2290/2025.

Dated: 30.05.2025

SANITARY AND NO OBJECTION CERTIFICATE

This is to certify that "SRI CHAITANYA HIGH SCHOOL", situated at H.no. 10-4-2 to 10-4-2/13 Opp. Pista House, beside laxmi garden , Yenugonda, Mahabubnagar is having sufficient No. of toilets for boys and girls. The premises of the School building is clean. Hence in view of Sanitation there is No Objection to run the above said School in view of hygiene.

Commissioner

Mahabubnagar Municipal Corporation